

---

# Fire Suppression Tests Using a Handheld Water Mist Extinguisher Designed for Spacecraft Applications

SUPDET 2012 – Phoenix, AZ

Thierry Carriere ([thierryc@adatech.com](mailto:thierryc@adatech.com)), ADA Technologies

Sayangdev Naha ([sayangdevn@adatech.com](mailto:sayangdevn@adatech.com)), ADA Technologies

Andrew Brewer ([andrewb@adatech.com](mailto:andrewb@adatech.com)), ADA Technologies

Angel Abbud-Madrid<sup>2</sup> ([aabbudma@mines.edu](mailto:aabbudma@mines.edu)), Colorado School of Mines


SUPDET 2012 – Phoenix, AZ

# NASA Need: New ISS Handheld Extinguisher

- Current ISS CO<sub>2</sub> Fire Extinguisher has cryogenically formed stainless steel tank
- Volume: 881 in<sup>3</sup> (~3.8 gal)
- Size: 11 in diameter, 15 in tall
- Weight: 15 lbm (full), 6 lbm (CO<sub>2</sub> charge)
- Discharge time: 45 seconds
- Nozzles are optional
- Operation: Push pin, remove pip pin, aim and squeeze handle
- ISS Quantity: presently 13
- **Issue: local CO<sub>2</sub> levels will be well above flight rule limits if fully discharged**



ISS Locker Stowed CO2 PFE




# ADA Technologies Water Mist Extinguisher

- NASA recommended the development of a non-CO<sub>2</sub> based PFE to reduce crew exposure to CO<sub>2</sub> toxicity during fire response and post-fire cleanup.  
Requirements: (1) be safe to use without PPE, (2) extinguish rack (hidden) and open cabin fires, (3) not hurt the vehicle.  
Fine Water Mist (FWM) PFE meets these criteria.
- NASA has funded ADA to develop advanced prototypes.


*“Off-the-shelf”  
tank prototype*



*Only water and nitrogen  
are discharged*




*Fine water spray  
fully characterized*



# Fine Water Mist Characteristics

Fine droplets → higher surface area for evaporation/cooling + radiation absorption and scattering




For each sprinkler droplet, the ADA mist has 60,000 smaller ones, offering 150x surface area

(assuming mist mean 50  $\mu m$  diameter droplets)

Fig. 3. Number of droplets and total surface area produced by one litre of water, as monodisperse sprays with various mean droplet diameters,  $d$  [10]. Reproduced from O. Herterich, Water as an extinguishing agent (published by Alfred Huthig Publishing Company, Heidelberg, 1960).

# FWM PFE Conceptual Architecture Overview

- Two primary system components: the **Tank Housing** and the **Nozzle Assembly**.
- Nozzle Assembly: controls the flow of water and expellant gas from the tank. Activated by the operator after removal of the safety pin and by manual action.
- Tank Housing: maintains the contents of the extinguisher at pressure actuation. The tank contains water and expellant gas separated by a physical barrier until mixed in the Nozzle Assembly.
- The inert gas propels the mist cloud from the extinguisher into the fire-affected zone.
- Discontinuing the manual action stops the flow of gas and water.



(Notional)






# Development of Fire Test Scenarios

---

- Objective: define standard fire tests for ISS
- The scenarios (based on risk assessment for ISS):
  - **Rack Fire Test (ISS enclosed volume)**
  - Open Cabin Fire Test
  - **Stored Energy Battery Fire Test**
  - Stored Energy Oxygen Candle Fire Test
  - Elevated Oxygen Fire Test
- Design of Experiments (DOE) was employed where it aided in determining significance of variables and interactions
- For the International Space Station (ISS) application these fire test standards will become the basic performance criteria for the Fine Water Mist Portable Fire Extinguisher (FWM PFE)

# Rack Fire Test Configuration



# Rack Fire Test Methodology

---

- Test Parameters

- Flight-like ISS rack divided into 3 volumes (2 equal volumes, left and right front boxes and a common back rack box)
  - Rack size and shape were set to flight-like structure
  - Volume size and shape were set by engineering conservatism
- Simulate use of ISS fire port access hole. Two fire port locations were defined on left volume.
- Fires and locations: Used 3 fires in right volume in top, middle and bottom locations
- Fuel: Liquid heptane, burns in low oxygen environment, simple, reproducible, same as FAA standard
  - 35 mm diameter cup
  - 5 ml heptane on top of 10 ml water



# Rack Fire Test Methodology (cont.)

---

- Test Variables

- Agent: Watermist, Low Pressure N<sub>2</sub>, High Pressure N<sub>2</sub>, CO<sub>2</sub>
- Packing Density/Configuration:
  - Preliminary tests: empty rack, with/without obstruction
  - Packing of rack to reduce internal volume by 50% and 75% (keep “duct holes” clear of obstruction)
  - Force suppressant to travel a tortuous path (at least 6 x 90° turn)

- Test Operations

- Ignite fuel and close rack, pre-burn 30 sec
- Fully discharge PFE into left volume
- Observe extinguishment of flame
- Open rack and re-ignite flame to confirm that fuel did not run out

# Rack Fire Tests Results

Run No.	Whole Plots	Agent	Configuration - Pack Density	Fireport	Time to Extinguish Fire 1 (BOTTOM)	Time to Extinguish Fire 2 (MIDDLE)	Time to Extinguish Fire 3 (TOP)
1	1	FWM	Simple 75%	High (3)	14	25	2
2	1	CO2	Simple 75%	High (3)	4	3	1
3	1	CO2	Simple 75%	Low (2)	5	8	13
4	1	HPN2	Simple 75%	Low (2)	5	7	8
5	2	FWM	Tortuous 75%	High (3)	28	9	3
6	2	LPN2	Tortuous 75%	High (3)	12	6	1
7	2	HPN2	Tortuous 75%	Low (2)	13	6	4
8	2	CO2	Tortuous 75%	High (3)	3.5	1	1
9	3	HPN2	Tortuous 50%	High (3)	6	12	9
10	3	FWM	Tortuous 50%	High (3)	43	52	58
11	3	LPN2	Tortuous 50%	Low (2)	NE	NE	99
12	3	CO2	Tortuous 50%	High (3)	6	14	34
13	4	LPN2	Simple 75%	High (3)	14	14	1
14	4	LPN2	Simple 75%	Low (2)	12	9	9
15	4	HPN2	Simple 75%	High (3)	2	1	1
16	4	FWM	Simple 75%	Low (2)	22	13	6
17	5	LPN2	Tortuous 75%	Low (2)	48	22	12
18	5	HPN2	Tortuous 75%	High (3)	2.5	2	1
19	5	FWM	Tortuous 75%	Low (2)	43	23	30
20	5	CO2	Tortuous 75%	Low (2)	11	9	8
21	6	CO2	Tortuous 50%	Low (2)	10	36	NE
22	6	FWM	Tortuous 50%	Low (2)	NE	100	89
23	6	LPN2	Tortuous 50%	High (3)	18	46	67
24	6	HPN2	Tortuous 50%	Low (2)	16	26	39
25	7	FWM	Simple 50%	High (3)	15	39	54
26	7	CO2	Simple 50%	Low (2)	11	23	52
27	7	CO2	Simple 50%	High (3)	12	11	14
28	7	LPN2	Simple 50%	Low (2)	73	53	75
29	8	HPN2	Simple 50%	High (3)	7	5	4
30	8	HPN2	Simple 50%	Low (2)	44	12	13
31	8	FWM	Simple 50%	Low (2)	54	NE	101
32	8	LPN2	Simple 50%	High (3)	14	28	37


# Rack Fire Tests Conclusions

---


- All agents were generally successful but experienced at least one failure to extinguish
- High momentum extinguishers (CO<sub>2</sub>, HPN<sub>2</sub>) extinguished flames in less time than LPN<sub>2</sub> and FWM. However, some flames were blown due to flow turbulence out rather than extinguished via inerting
- Finest droplets of FWM were observed to travel through tortuous path but did not seem to accelerate extinguishment (compared to N<sub>2</sub> only)
- Identified most challenging configuration for NASA standard test (middle fire port, middle flame, low turbulence)
- Next step: repeat tests in now standard configuration to improve statistical analysis

# Battery Fire Overall Set Up - Schematic

Side View



Top View



# Battery Fire Configuration / Technique

---


## Test Parameters

- Ignition via overheating
- 2 stacked 4 cell camcorder battery pack (1<sup>st</sup> is igniter, 2<sup>nd</sup> is propagation)
- Spark ignition source to increase ignition repeatability

## Test Operations

- Full engulfment of igniter battery: 15 seconds after 4 cells of igniter battery visually vented + witness PMMA ignited
- Firefighter starts discharging extinguisher (5.5 ft away) from fixed location, pulsing as needed and cooling test articles
- Pass/ Fail: all flames fully extinguished, stop thermal runaway leading to re-ignition and propagation (batteries or materials)
- Monitor: 15 minutes post extinguishment
  
- Note: to be valid, test should not have cells ejected




# Results – Battery Fire Extinguished with FWM



Stacked battery packs. Colored dots represent location of TC's

- Flames extinguished. Thermal runaway stopped after 1 re-ignition
- Temperature cooling clearly observed with FWM FTE pulses

# Results – Comparison with Baseline Tests (free burn)



- FWM FE tests lowered max 1300°F to 900°F
- FWM FE tests lowered event duration time from max 41min to 22min

# Results – Post-test Visual Inspection

## Baseline




## Test with Extinguisher



- Baseline fully consumed casing and vented cells
- FWM extinguisher tests stopped propagation leaving casing material and an average of 2 cells with charge  $>0$




# Results – Battery Fire Extinguished with CO<sub>2</sub>



Stacked battery packs. Colored dots represent location of TC's

- 3 tests with commercial 14 lb handheld CO<sub>2</sub> conducted
- 2 tests required 5.9 lb and 9.1 lb to extinguish fire, with one cell lost
- Fire not extinguished with full 14 lb in third case
- For comparison, ISS uses 6.5 lb CO<sub>2</sub> extinguisher

# Results – Battery Fire Not Extinguished with CO<sub>2</sub>



- 6 reignitions occurred using 14 lbs of CO<sub>2</sub> extinguisher
- Max 1 reignition seen with FWM, stopping thermal runaway and propagation

# Summary and Conclusions – Battery Fire Tests

---

- **Fine Water Mist Test Conclusions:**
  - In 5/5 tests, all flames were fully extinguished
  - In 5/5 tests, cooling was sufficient to prevent continuation of thermal runaway and consumption of propagation battery pack
  - FWM left casing material and an average of 2 cells with charge >0
  - Baseline tests fully consumed casing and vented all cells
  - Additional Findings
    - FWM lowered max temp from 1300°F to 900°F
    - FWM lowered event duration time from max 41 min to 22 min
    - ISO Environmental Calorimeters saw a worst case 5.5 F increase in environmental temperatures (No keep out zone implications)
    - No oxygen depletion was observed (No keep out zone implications)
- **CO<sub>2</sub> Test Conclusions:**
  - More difficulties extinguishing fires (2/3 tests)
  - 1/3 test not extinguished with 14 lbs when all cells present